

Local Work Instruction:**Noble Discoverer: Non-contact Cooling Water Discharge for HVAC and Refrigeration Units – D009****Approved By:****Scope:****Issue Date:****Revision level:****Written By:****Revised By:****Revision/Review Date:****Next Review Date:**

Buddy Brooks

R. Leberman / D. Johnson

SCOPE:

This document offers work level instructions associated with discharging non-contact cooling water from HVAC and refrigerator units, while operating under the guidelines of the NPDES General Permit (AKG-28-8100), onboard the *Noble Discoverer*. Non-contact cooling water consists of seawater used to cool installed machinery such as the HVAC air conditioning units, cement units, compressors, generators, desalination units, rectifiers, and hydraulic equipment (rig brakes) located at various places on the *Noble Discoverer*. No biocides or chemicals will be added to this system. All primary cooling water is contained in a closed loop system. All of the HVAC units, cement units, compressors, rectifiers and hydraulic equipment discharge above seawater surface. All secondary cooling loops including the port generators, one re-circulation loop, and desalination units are sent through a Sea Suction Strainer/Colander installed underwater to prevent "sizeable" sea life from being affected by the discharge back to the ocean. No intermixing of fresh and salt water occurs between the primary and secondary loops.

In addition, independent digital flow meters along with temperature sensors have been installed on several discharge lines to monitor flow and temperature

RESPONSIBILITY:

The M-I SWACO Compliance Specialist is responsible to ensure that this LMI has been provided to each person prior to conducting this task for the first time. During active drilling operations, the M-I SWACO NPDES Compliance Specialist is responsible for performing the following tasks on a daily basis for each of the non-contact cooling water discharges:

- Document the flow volume from the effluent flow meters.
- Perform and document visual sheen tests for each outfall.
- Temperature will be monitored continuously and documented for non-contact cooling water (009).
- Four times per well, at intervals designated to be representative of the discharge's toxicity, a sample will be collected for initial toxicity screening. Each sample will be collected at a time period selected to reflect discharge processes and operational processes. Collect and document initial toxicity screening samples.
- WET testing will be required if either of the following occurs: 1) Initial rapid toxicity screening threshold criteria are exceeded OR 2) discharge exceeds 10,000 gallons during any 24-hr period and chemicals are added to the system. If WET testing is required, collect and document three samples from the OWS effluent on an every-other-day basis. Package samples for transport to the fixed analytical laboratory.
- Collect and document samples for pH analysis.

1.0 References:

- 1.0 NPDES GP AKG-28-8100:
 - 1.0.1 Table 10-Effluent Limitations and Monitoring Requirements for Non-contact Cooling Water (D009).
- 1.1 Noble As-Built 1599-6009
- 1.2 Figure 1 - Discharge Points (Weston)
- 1.3 Noble Discoverer Best Management Practices, April 2015
- 1.4 Noble Discoverer Quality Assurance Project Plan, April 2015
- 1.5 M-I SWACO Standard Operating Procedures: 1006, 3005, 2001, 2012, LVM-001, ENV001.01, TOX045.02, TOX002.05, TOX012.06, TOX014B.02, TOX043.06.
- 1.6 Shell Exploration & Production Company Alaska Venture 2015 Noble Discoverer Waste Management Plan.

2.0 General Requirements:

- 2.0 The M-I SWACO NPDES Compliance Specialist is responsible for discharge sampling, testing, and reporting to the Shell Environmental Department while operating under NPDES GP AKG-28-8100.
- 2.1 The Shell Environmental Department is responsible for maintaining the Discharge Monitoring Report (netDMR) and submitting to EPA all discharges sampling, testing and results on a monthly basis.
- 2.2 The Noble is responsible for operating and repairing all equipment associated with this discharge.

3.0 Safety Guidelines:

- 3.0 Before any operations can take place, all personnel involved in this process must complete the following details if required by operator or contractor:
 - 3.0.1 The Pre-Tour Meeting is when daily activities are discussed.
 - 3.0.2 Job Safety Analysis with all involved parties present.
 - 3.0.3 Review Risk Assessment, if applicable.
 - 3.0.4 Noble Permit to Work.
- 3.1 Appropriate personal protective equipment must be worn at all times.

4.0 Discharge/Task Description:

- 4.0 Seawater is withdrawn through a sea chest located in the Main Engine Room and is used to cool the HVAC and Refrigeration units located on the vessel. Seawater is circulated through the condensers before being discharged back to receiving waters through a 6" pipe located on the starboard side of the vessel in the Main Engine Room.
- 4.1 Prior to being discharged, the effluent temperature is measured by a sensor installed near the discharge points. The data is logged every hour and the high and low values are recorded daily. In the event a temperature sensor fails, the M-I SWACO NPDES Compliance Specialist will collect samples and manually measure the temperature every 6 hours. Observations will be recorded on the NPDES Master Spreadsheet.
- 4.2 An inline flow meter displays the velocity of flow in real time and is also stored on a data logger. The rate of flow can be viewed directly from the meter or collected from the data logger. In the event that a flow meter fails, estimates will be based on historical data. Total gallons discharged will be recorded on the NPDES Master Spreadsheet on a daily basis for netDMR reporting. Samples will be collected in accordance with the QAPP.
- 4.3 The M-I SWACO NPDES Compliance Specialist will conduct a free oil test using the visual sheen method on a daily basis while operating under the NPDES GP. Visual sheen tests will be performed during daylight hours while the receiving water can be seen. The M-I SWACO NPDES Compliance Specialist will record visual sheen observations on the NPDES Master Spreadsheet.
- 4.4 A Sample port has been installed near the discharge locations on starboard side. Samples needed for analytical testing (Initial toxicity, pH, and WET) will be collected using this port as described in section 5.0 below.

- 4.5 The M-I SWACO NPDES Compliance Specialist will immediately report to Shell Environmental Department at 907-830-7435, of any upset condition.

5.0 Sampling Plan for Non-contact Cooling Water (D009):

Effluent Parameter	Effluent Limitations		Monitoring Requirements	
	Average Monthly Limit	Maximum Daily Limit	Sample Frequency	Sample Type
pH	Report (s.u.)		Monthly	Grab
Free oil	No discharge		Daily	Visual
Total Volume	Report (gal)		Daily	Flow Meter
Temperature	Report (°F)		Continuous	Measure
WET	Report (TU _c)		Use rapid toxicity test 4X/well as initial screen. WET not needed if initial passes.	Collect grab sample for analysis if results show potential toxicity or 1X/well if discharge >10,000 gal during 24 hr and if chemicals are added to the system.

6.0 Clean-up:

- 6.0 Follow housekeeping practices.

7.0 Contingency:

- 7.0 Notify rig personnel if any equipment isn't working properly.

Revision Log:

Date:	Document History:	Revised/reviewed by:	Location:

Document Number:

Print Date: 5/26/2015

PAPER COPIES ARE UNCONTROLLED. THIS COPY VALID ONLY AT THE TIME OF PRINTING. THE CONTROLLED VERSION OF THIS DOCUMENT CAN BE FOUND ON THE ALASKA E-COLLABORATION SITE.